BOM Standard Tags

Standard Engineering Practices

Document: 5.2
Date 11-12-01
Supersedes:

Temperature Sensors

Designation	Description
TS1	Return Air Temperature Sensor
TS2	Mixed Air Temperature Sensor
TS3	Discharge Air Temperature Sensor
TS4	Space Temperature Sensor
TS5	Hot Water Supply Temperature Sensor
TS6	Hot Water Return Temperature Sensor
TS7	Outside Air Temperature Sensor
TS8	Chilled Water Supply Temperature Sensor
TS9	Chilled Water Return Temperature Sensor
TS10	Condensor Supply Temperature Sensor
TS11	Condensor Return Temperature Sensor
TS12	Hot Deck Temperature Sensor
TS13	Cold Deck Temperature Sensor
TS14	Preheat Temperature Sensor
TS15	Dual Temperature Supply Sensor
TS16	Dual Temperature Return Sensor
TS17	Glycol Supply Temperature Sensor
TS18	Glycol Return Temperature Sensor
TS19	Domestic Hot Water Temperature Sensor

Fan or Pump Flow Status Devices

Designation	Description
DP1	Pump1 Flow Status
DP2	Pump2 Flow Status
DP1 or CT1	Supply Fan Status
DP2 or CT2	Return Fan Status

Confidential Information for Invensys Energy Solutions Employees and Affiliates
Building Systems - Americas
© 2002 Invensys. All Rights Reserved.

Dampers

Designation	Description
D1	Outside Air
D2	Return Air
D3	Exhaust Air
D4	Face Damper
D5	By-Pass Damper

Humidity Transmitters

Designation	Description
HS1	Return Air Humidity Transmitter
HS3	Discharge Air Humidity Transmitter
HS4	Space Humidity Transmitter
HS7	Outside Air Humidity Transmitter
HTS1	Outside Temperature and Humidity Dual Transmitter

Safety Limit Thermostats

Designation	Description
LL1	Low Limit Thermostat
HL1	High Limit Thermostat

Confidential Information for Invensys Energy Solutions Employees and Affiliates
Building Systems - Americas
© 2002 Invensys. All Rights Reserved.